

# TYPE APPROVAL CERTIFICATE

**This is to certify:****That the FRP Grating**

with type designation(s)  
**FRP moulded gratings**

Issued to

**Lichtgitter GFK GmbH & Co. KG**  
**STADTLOHN, Germany**

is found to comply with  
**DNV GL offshore standards**  
**DNV GL rules for classification – Ships**  
**DNV GL statutory interpretations DNVGL-SI-0364 – SOLAS interpretations**

**Application :**

**For use in locations according to enclosed Structural Fire Integrity Matrix.**

**Application is to be considered and accepted for each case/project.**

**Product approved by this certificate is accepted for installation on all vessels classed by DNV GL.**

Issued at **Hamburg** on **2021-02-08**

This Certificate is valid until **2026-02-07**.

DNV GL local station: **Essen**

Approval Engineer: **Timo Linn**



for **DNV GL**

Digitally Signed By: Kallies,  
Joerg  
Location: DNV GL Hamburg, Germany  
Signing Date: 23.02.2021

**Jörg Kallies**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV GL AS, its parent companies and subsidiaries as well as their officers, directors and employees ("DNV GL") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Job Id: **262.1-034525-1**  
Certificate No: **TAF00001GX**

## Product description

Different variants of FRP moulded gratings manufactured using fire retardant polyester resins

Based on the results of ASTM E84, among the results of the tested models, the maximum FSI and maximum SDI are deemed to be represented by the types of Grating. The FRP grating models have been reported as FSI < 25 and SDI < 450.

Structural Fire Integrity Level according to (ASTM F3059) "L0"

## Grating Type Matrix

	Surface					type	Sizes			
	K/KS	BK/BQ/BKS/BQS	G/GS	GES	SAND		height	bar top	bar	mesh
	(concave)	(gritted)	(grinded,	(closed surface)	(sandwich)		(mm)	(mm)	(mm)	(mm)
		BK = 1.0 - 1.4 mm			(top & bottom closed)					
1	K	BK	G			525-38-5	25.00	6.25	5.00	38.1 x 38.1
2	K	BK	G			525-40-5	25.00	6.25	5.00	40.0 x 40.0
3	K	BK	G			530-20-5	30.00	6.50	5.00	20.0 x 20.0
4	K	BK	G	GES	SAND	530-38-5	30.00	6.50	5.00	38.1 x 38.1
5	K	BK	G			530-40-5	30.00	6.50	5.00	40.0 x 40.0
6	K	BK	G			538-19-5	38.00	6.90	5.00	19.05 x 19.05
7	K	BK	G	GES	SAND	538-38-5	38.00	6.90	5.00	38.1 x 38.1
8	K	BK	G			538-40-5	38.00	6.90	5.00	40.0 x 40.0
9	K	BK	G			550-25-5	50.00	7.50	5.00	25.4 x 25.4
10	K	BK	G	GES	SAND	550-38-5	50.00	7.50	5.00	38.1 x 38.1
11	KS	BKS/BQS	GS	GESS	SANDS	750-38-7	50.00	9.00	6.50	38.1 x 38.1
12	KS	BKS/BQS	GS	GESS	SANDS	950-38-9	50.00	11.00	9.00	38.1 x 38.1
13	KS	BKS/BQS	GS	GESS	SANDS	960-38-9	60.00	11.00	9.00	38.1 x 38.1
14	KS	BKS/BQS	GS			950-25/50-	50.00	11.00	9.00	25.4 x 50.9

For further details refer to the documentation listed below under "Type Examination documentation".

## Application/Limitation

The FRP grating is only evaluated in accordance with fire technical requirements. Other requirements such as strength etc. has to be evaluated in each case according to the applicable standard.

for use in locations according to the below Structural Fire Integrity Matrix

Structural Fire Integrity Matrix (ASTM F3059-18)

Location	Service	Fire Integrity
Machinery Spaces	Walkways or areas which may be used for escape, or access for fire fighting, emergency operation or rescue	L1 <sub>1</sub>
	Personnel walkways, catwalks, ladders, platforms or access areas other than those described above	L3
Cargo Pump Rooms	All personnel walkways, catwalks, ladders, platforms or access areas	L1
Cargo Holds	Walkways or areas which may be used for escape, or access for fire fighting, emergency operation or rescue	L1
	Personnel walkways, catwalks, ladders, platforms or access areas other than those described above	L0
Cargo Tanks	All personnel walkways, catwalks, ladders, platforms or access areas	L0 <sub>2</sub>

Job Id: **262.1-034525-1**  
Certificate No: **TAF00001GX**

Fuel Oil Tanks	All personnel walkways, catwalks, ladders, platforms or access areas	L0
Ballast Water Tanks	All personnel walkways, catwalks, ladders, platforms or access areas	L0
Cofferdams, void spaces, double bottoms, pipe tunnels, etc.	All personnel walkways, catwalks, ladders, platforms or access areas	L0
Accommodation, service, and control spaces	All personnel walkways, catwalks, ladders, platforms or access areas	Not permitted
Lifeboat embarkation or temporary safe refuge stations in open deck areas	All personnel walkways, catwalks, ladders, platforms or access areas	L2
Open Decks or semi-enclosed areas	Operational areas and access routes for deck foam firefighting systems on tank vessels	L2
	Walkways and areas that may be used for escape, or access for firefighting systems and AFFF hose reels, emergency operation, or rescue on MODUs and production platforms including safe access to tanker bows	L2 <sub>4</sub>
	Walkways or areas that may be used for escape or access for firefighting, emergency operation or rescue other than those used above	L3
	Personnel walkways, catwalks, ladders, platforms or access areas other than those described above	L3
	Gangway for safe access to bow on tankers according to IMO MSC.62(67)	L2 <sub>3</sub>

**Footnote:**

- 1) If machinery space does not contain any internal combustion machinery, other oil burning, oil heating or oil pumping units, fuel oil filling stations, or other potential hydrocarbon fire sources and has not more than 2.5 kg/m<sup>2</sup> of combustible storage, gratings of L3 integrity may be used in lieu of L1.
- 2) Gratings that are electrically conductive shall be required. Acceptance criteria for resistance per unit length and to earth is: < 0.1 M  $\Omega$  to earth. Test standard ASTM D257-91, ref. DNV GL-CP-0070 "Fibre reinforced thermosetting plastic piping systems - Non-metallic materials"
- 3) Also required to be tested according to IMO 2010 FTP Code Part 5 and 2 for floor covering (IMO MSC.1/Circ.1504).
- 4) Tested with furnace temperature curve according to ASTM E119 (i.e. not tested for Hydrocarbon or Jet fire exposure).

Job Id: **262.1-034525-1**  
Certificate No: **TAF00001GX**

This Certificate does not cover testing of the FRP grating subjected to Hydrocarbon or Jet fire exposure. DNV GL recommend that for any area where FRP grating is arranged and with possible exposure to

Hydrocarbon or Jet fire, Risk Assessment is conducted to ensure that the use of FRP does not have any negative effect with respect to Escape, Safe Evacuation, Firefighting and Escalation of the original fire incident.

Each product is to be supplied with its manual for installation and maintenance.

## **Type Approval documentation**

Certification in accordance with Class Programme DNVGL-CP-0338, September 2018.

Test Report No. 200901005SHF-001 to 014 dated 2020-11-04 from Intertek Testing Services Ltd., Texas, USA.

Lichtgitter Data Sheet Types description (spezifikation & sizes), dated 2021 from Lichtgitter GFK GmbH & Co. KG.

Summary of test results:

Letter Report No: 200901005SHF-019 dated 2020-11-10 from Intertek Testing Services Ltd., Shanghai Fengxian Branch Plant 5, Shanghai, China

## **Tests carried out**

Tested according to ASTM F3059 and ASTM E84.

Structural fire integrity was tested with furnace temperature curve according to ASTM E119.

## **Marking of product**

Each FRP grating shall be marked as a minimum with the brand and the appropriate fire rating (L1, L2, L3 or L0). The label shall be molded into the grating or included on a permanently attached label.

## **Periodical assessment**

DNV GL's surveyor is to be given permission to perform Periodical Assessments at any time during the validity of this certificate and at least every second year. The arrangement is to be in accordance with procedure described in Class Programme DNVGL-CP-0338, Section 4.

## **Place of production**

Lichtgitter GFK - GmbH & Co. KG, Siemensstraße 6, 48703 Stadthoorn